

ENVIRONMENTAL PROTECTION AGENCY
REGION II
EDISON, NEW JERSEY 08817

REPLY TO
ATTN OF:

2-SA-ER

DATE: May 26, 1976

SUBJECT:

Reinspection of Troy Chemical on 5/25/76

TO:

Michael V. Polito, Chief *MP*
Emergency Response & Inspection Branch

ENVIRONMENTAL PROTECTION AGENCY
REGION II, BUILDING 209
EDISON, NEW JERSEY 08817

The area of soil contaminated with hexoates has been dug up and is to be taken to Kin Buc. The stream bank is being protected from further leakage to the stream by the installation of a concrete dike along the stream. In addition, a curbing is being installed along the length of the plant reaction area bordering the stream.

In addition, I noticed that a mineral spirits storage tank was not diked. Inspection of their SPCC Plan indicated that the Plan covers only their fuel oil storage tanks. They store seven materials which are also oils which should be covered by the SPCC Plan. This matter was referred to Clark Price.

Arthur H. Gevirtz

Arthur H. Gevirtz
Hazardous Substances Spill Response Officer
Emergency Response & Inspection Branch

